



**NOTE:**

1. CUSTOMER OWNED POLE CONSTRUCTED TO OES STANDARD AND HOB REQUIREMENTS.
2. CUSTOMER OWNED SERVICE MAST, DISCONNECT SWITCH AND METER BASE MUST MEET ESA APPROVAL.
3. CUSTOMER TO CONSULT HOB FOR LIST OF APPROVED METER BASES.
4. SERVICE CONDUCTORS MUST MAINTAIN MINIMUM CLEARANCE OF 6.0m (20 FT.) OVER AREAS ACCESSIBLE BY VEHICLES.
5. GUYING TO BE INSTALLED BY CUSTOMER.

<u>REFERENCE</u>	<u>SECTION</u>
LINE CLEARANCES MATERIAL	03 15

CHECKED: *W. Iron*

APPROVED IN ACCORDANCE WITH REGULATION 22/04

APPROVED: *Chakraborty*

TYPICAL TEMPORARY O/H  
SERVICE TAP CONNECTION